

PLATFORM ELECTRICAL SYSTEMS

(Last Update – February 2018)

(Note: Refer to Appendix 20 for all Electrical System PINC's and associated definitions.)

ClassifiedAreas

F- 101	HAS THE LESSEE SUBMITTED A PLAN CLASSIFYING <u>Authority</u> : 30 CFR 250.842(a)(3)	ALL HAZARDOUS AREAS? <u>Enforcement Actions</u> : W		
	Batte	eries_		
F-103	ARE ALL RECHARGEABLE BATTERY SYSTEMS INSTALLED SUCH THAT HYDROGEN CANNOT COLLECT IN SUFFICIENT QUANTITIES TO CREATE A HAZARD AND TO PROTECT THE BATTERIES IN ACCORDANCE WITH AIRP 14F, PARAGRAPHS 10.3.4.2 AND 10.3.4.3, AND API RP 14FZ, PARAGRAPHS 10.3.4.2 AND 10.3.4.3?			
	Authority: 30 CFR 250.114	Enforcement Actions: W/C		
	Lighting	<u>Fixtures</u>		
F-104	ARE LIGHTING FIXTURES INSTALLED IN CLASSIFIED LOCATIONS SUITABLE FOR THE PARTICULAR LOCATION AND PROTECTED FROM DAMAGE IN ACCORDANCE WITH API RP 14F, PARAGRAPHS 9.3.3.3 AND 9.3.3.6, OI API RP 14FZ, PARAGRAPHS 9.3.3.3 AND 9.3.3.6?			
	Authority: 30 CFR 250.114(a)	Enforcement Actions: C		
	_			
	Portable Electrical,	/Electronic Devices		
F-105	•	ELECTRICAL TOOLS USED IN CLASSIFIED LOCATIONS JNCTION WITH A HOT WORK PERMIT IN ACCORDANCE RP 14FZ, PARAGRAPH 12.3, 12.4?		
	Authority: 30 CFR 250.114	Enforcement Actions: C		

F-106	DO PORTABLE ELECTRICAL TOOLS HAVE WARNING LABELS CERTIFYING THEIR USE IN CLASS I, GROUP D LOCATIONS OR ARE THEY PERMANENTLY LABELED "WARNING SOURCE OF IGNITION WHEN IN USE,", IN ACCORDANCE WITH API RP 14F, PARAGRAPH 12.3.4; OR API RP 14FZ, PARAGRAPH 12.3.4?			
	Authority:	30 CFR 250.114	Enforcement Actions: C	
	_			
		<u>Installation/Maintenance</u>		
F-108	ARE ELECTRICAL INSTALLATIONS MADE IN ACCORDANCE WITH API RP 500 AND API RP 14F OR API RP 505 AND API RP 14FZ?			
	<u>Authority</u> :	30 CFR 250.114 (a) 30 CFR 250.114(c)	Enforcement Actions: W/C/S	
	_			
		<u>Wiringand Grounding</u>		
F-121		TAL EQUIPMENT, SUCH AS BUILDINGS, VESSELS, AND S NDING NETWORK IN ACCORDANCE WITH API RP 14F, F PH 6.10.3?		
	Authority:	30 CFR 250.114	Enforcement Actions: C	
	_			
F-122	DO ALL FLEXIBLE STEEL CONDUITS BEING UTILIZED FOR TERMINAL CONNECTIONS TO MOTORS, MOTOR DRIVEN EQUIPMENT, MOTOR TERMINAL BOXES, TRANSFORMERS, AND OTHER VIBRATING EQUIPMENT CONTAIN A SEPARATE EXTERNAL GROUNDING CONDUCTOR IN ACCORDANCE WITH API RP 14F, PARAGRAPH 6.4.7.3.2, AND API RP 14FZ, PARAGRAPH 6.4.7.3.2?			
	Authority:	30 CFR 250.114	Enforcement Actions: W	
	_			
F-124		ISION CORDS USED ONLY FOR TEMPORARY USE AND D OR IN ACCORDANCE WITH API RP 14F, PARAGRAPH 12		
	Authority:	30 CFR 250.114 (c)	Enforcement Actions: C	
	=			

Authority:	30 CFR 250.114 30 CFR 250.114(c)	Enforcement Actions: W
_		
IS ALL PURGED AND PRESSURIZED ELECTRICAL EQUIPMENT INSTALLED AND MAINTAINED WITHIN CLASSIFIED AREAS IN ACCORDANCE WITH API RP 14F, PARAGRAPH 4.3.5, AND API RP 14FZ, PARAGRAPH 4.3.5?		
<u>Authority</u> :	30 CFR 250.114 30 CFR 250.114(c)	Enforcement Actions: W
_		
	<u>Lockout/Tagou</u>	<u>rt Procedures</u>
DOES THE FACILITY HAVE AN ELECTRICAL LOCKOUT/TAGOUT PROCEDURE IN ACCORDANCE WITH API RP 14F, PARAGRAPH 12.8 OR API RP 14FZ, PARAGRAPH 12.9?		
<u>Authority</u> :	30 CFR 250. 114(c)	Enforcement Actions: C
_	Nameplate Ir	nformation_
ARE PERMANENT NAMEPLATES ATTACHED TO ALL TRANSFORMERS AND DOES THE NAMEPLATE PROVIDE THE INFORMATION IN ACCORDANCE WITH API RP 14F, PARAGRAPH OR API RP 14FZ, PARAGRAPH 8.2.3.1.2?		
Authority:	30 CFR 250.114(c)	Enforcement Actions: C
	CLASSIFIED 1.3.5? Authority: DOES THE F 14F, PARAG Authority: ARE PERMA THE INFOR	Authority: 30 CFR 250.114 30 CFR 250.114(c) Lockout / Tagou DOES THE FACILITY HAVE AN ELECTRICAL LOCKOUT 14F, PARAGRAPH 12.8 OR API RP 14FZ, PARAGRAPH Authority: 30 CFR 250. 114(c) Nameplate In